

Cement Test Certificate

Final

Lot 242 Russell Road East, Munster WA 6166 PO Box 38, Hamilton Hill WA 6963 T: +61 8 9411 1000 F: +61 8 9411 1150

Product Certified: Type GP Coarse General Purpose Cement

Test Certificate Number: 220098

Produced At: Cockburn Cement, Kwinana Plant, WA

Sample Code: B08b3ad Sample Date: 4/02/2022

| Nominal Blend | Requirements | Result |
|---|--------------|--------|
| Clinker | | >95 % |
| Ground Granulated Iron Blast-Furnace Slag | | Nil |
| Mineral Addition | Max 7.5 % | Nil |
| Calcium Sulphate | | 5% |
| Minor Additional Constituents | Max 5 % | Nil |

| Reportable Property | Test Method | Requirements of | Dogult |
|---|-------------|-----------------|-----------|
| | | AS3972 | Result |
| 3 Day Strength | AS2350.11 | N/R | 39.2 MPa |
| 7 Day Strength | AS2350.11 | Min 35.0 MPa | 48.4 MPa |
| 28 Day Strength | AS2350.11 | Min 45.0 MPa | 61.2 MPa |
| Initial Set Time | AS2350.4 | Min 45 min | 120 min |
| Final Set Time | AS2350.4 | Max 360 min | 165 min |
| Soundness | AS2350.5 | Max 5 mm | 1 mm |
| Sulfuric Anhydride content (SO ₃) | AS2350.2 | Max 3.5 % | 3.1 % |
| Chloride Ion | BH-TM-0507 | Max 0.10 % | 0.013 % |
| Other Properties | | | |
| SiO ₂ | AS2350.2 | N/R | 20.4 % |
| Al_2O_3 | AS2350.2 | N/R | 5.5 % |
| Fe_2O_3 | AS2350.2 | N/R | 2.9 % |
| CaO | AS2350.2 | N/R | 64.4 % |
| MgO | AS2350.2 | N/R | 1.4 % |
| Na ₂ O Equivalent | AS2350.2 | N/R | 0.6 % |
| Loss on Ignition | AS2350.2 | N/R | 1.1 % |
| Fineness Index | AS2350.8 | N/R | 360 m²/kg |
| Normal Consistency | AS2350.3 | N/R | 29.7 % |

 ${\it This\ document\ shall\ not\ be\ reproduced\ except\ in\ full.}$

REMARKS

These test result apply specifically to the sample as received at the Adelaide Brighton Cement Birkenhead Laboratory (Accreditation number: 252), 62 Elder Rd Birkenhead SA 5015.

This despatch grab sample complies to the requirements of AS3972:2010, Type GP Cement. $\mbox{N/R} = \mbox{No Requirement}$



Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Approved Signatory
M. Wythe

Issue Date: 19/03/2022